

**COUNCIL BILL NO. 1982**

**INTRODUCED BY: James Aughenbaugh**

**ORDINANCE NO. 1879**

**AN ORDINANCE**

**OF THE CITY OF DUBOIS AMENDING CHAPTER 340, ARTICLE V, SECTION 340-43.2. OF THE CODE OF ORDINANCES OF THE CITY OF DUBOIS TO UPDATE THE MAXIMUM ALLOWABLE LOADING LIMITS OF THE INDUSTRIAL SEWER USE REGULATIONS.**

**NOW, THEREFORE, BE IT ORDAINED AND ENACTED** by the Council of the City of DuBois, in Council assembled, and it is hereby enacted and ordained by authority of the same, as follows:

**Section 340-43.2. (4)C.** Chapter 340, Article V, Table entitled "Maximum Allowable Industrial Loading (lb/day)" that sets forth the accepted local limits at Maximum Allowable Industrial Loading, shall hereby be replaced with the following table:


Pollutant	Proposed Local Limit MAIL (lbs/d)	Basis of Limitation
Arsenic	0.3	Inhibition
Cadmium	0.009	Water Quality
Chromium	2.09	Water Quality
Copper	0.6	Water Quality
Cyanide	0.4	Water Quality
Lead	0.26	Water Quality
Mercury	0.0034	Water Quality
Molybdenum	0.109	Sludge
Nickel	0.83	Sludge
Silver	0.32	Water Quality
Zinc	4.7	Water Quality
TSS	850	Design
Bis(2-EthylHexyl)Phthalate	0.012	Water Quality
Di-N-ButylPhthalate	1.71	Water Quality
Chloroform	0.877	Water Quality


**Section 2.** All other portions of Chapter 340, Article V are hereby reaffirmed and re-ratified insofar as the same are not in conflict herewith.

**Section 3.** All other Ordinances or parts of Ordinances or Resolutions in conflict herewith be and the same are herewith repealed.

**Section 4.** The within Ordinance shall become effective upon final enactment hereof.

ATTEST:

  
 \_\_\_\_\_  
 City Manager

By   
 \_\_\_\_\_  
 Pat Reasinger  
 Mayor and President of Council

PASSED BY COUNCIL:

\_\_\_\_\_ March 25, 2024

APPROVED:   
 \_\_\_\_\_